

## Facility Summary in CHOUTEAU County in the City of BIG SANDY

**Location:** EZZIES WHOLESALE BIG SANDY  
 FERRY STAR ROUTE PO BOX 236  
 BIG SANDY, MT 59520 CHOUTEAU

**Sys Fac ID:** 08-00855

**Last Inspected On:** 3/20/2013

**Operating Permit Renewal Date:** 7/9/2016

**Contact:** (406) 378-2101

**Owners/Operators:** EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770  
 MALTA MT 59538-9640

David Skiff, UST Class A Operator  
 Kenneth Martin, UST Class B Operator  
 David Skiff, UST Class B Operator  
 David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	6/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>1841</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
4,000					
2	25	5/18/1990	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>1842</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
4,000					
3	23	6/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>1844</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
4,000					

## Facility Summary in CHOUTEAU County in the City of BIG SANDY

**Location:** EZZIES WHOLESALE BIG SANDY  
 FERRY STAR ROUTE PO BOX 236  
 BIG SANDY, MT 59520 CHOUTEAU  
**Contact:** (406) 378-2101

**Sys Fac ID:** 08-00855  
**Last Inspected On:** 3/20/2013  
**Operating Permit Renewal Date:** 7/9/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	23	6/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1845			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
4,000					
11	25	5/18/1990	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1843			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
2,000					

## Facility Summary in CHOUTEAU County in the City of BIG SANDY

**Location:** MOUNTAIN VIEW COOP BIG SANDY  
79211 US HIGHWAY 87  
BIG SANDY, MT 59520 CHOUTEAU

**Sys Fac ID:** 56-14150

**Last Inspected On:** 1/2/2014

**Operating Permit Renewal Date:** 4/27/2017

**Contact:** Chester Kallem, (406) 453-2435

**Owners/Operators:** Mountain View Coop, Owner

(406)-453-2435

ATTN DAVE DOUGLAS  
2200 OLD HAVRE HWY  
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator

David Douglas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	11	1/31/2005	Bare Steel	Flexible Plastic	High Level Alarm
<b>4965</b>	Yes	4/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
5,000		9/10/2014			
2	11	1/31/2005	Bare Steel	Flexible Plastic	High Level Alarm
<b>4966</b>	Yes	4/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000		9/10/2014			
3			Bare Steel	Flexible Plastic	
<b>4967</b>	Yes	4/15/2013	None	Double-Walled	Yes
Temporarily Out of Use				Pressurized	
Unknown			Deferred	Continuous Interstitial Monitor	
1					
4			Bare Steel	Flexible Plastic	
<b>4968</b>	Yes	4/15/2013	None	Double-Walled	Yes
Temporarily Out of Use				Not Listed	
Unknown			Deferred	Continuous Interstitial Monitor	
1					

## Facility Summary in CHOUTEAU County in the City of CARTER

**Location:** SCHULER LANDS EAST FARM  
17105 DENT BRIDGE RD  
CARTER, MT 59420 CHOUTEAU

**Sys Fac ID:** 08-03976

**Last Inspected On:** 8/8/2015

**Operating Permit Renewal Date:** 11/21/2018

**Contact:** Dale Schuler, (406) 734-5404

**Owners/Operators:** Schuler Lands Inc, Owner (406)-734-5404 17105 DENT BRIDGE RD  
CARTER MT 59420-0036  
Schuler Bros, Operator (406)-734-5404 17105 DENT BRIDGE RD  
CARTER MT 59420  
Dale Schuler, UST Class A Operator  
Dale Schuler, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	33	4/22/1982	Fiberglass Reinforced Plastic	No Piping	Flapper Valve (Auto Shutoff)
4133			None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
9,000			Gilbarco EMC Basic , Gilbarco		

## Facility Summary in CHOUTEAU County in the City of CARTER

**Location:** MALMSTROM AFB J 3  
 US HIGHWAY 87  
 CARTER, MT 59420 CHOUTEAU  
**Contact:** Jim Hodges,

**Sys Fac ID:** 08-09076  
**Last Inspected On:** 9/21/2015  
**Operating Permit Renewal Date:** 9/22/2018

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
 MALMSTROM AFB MT 59402-7536  
 Lana Hedlund, UST Class A Operator  
 James Hodges, UST Class A Operator  
 Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
157		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

## Facility Summary in CHOUTEAU County in the City of CARTER

**Location:** MALMSTROM AFB J 5  
US HIGHWAY 87  
CARTER, MT 59420 CHOUTEAU

**Sys Fac ID:** 08-09078

**Last Inspected On:** 9/21/2015

**Operating Permit Renewal Date:** 9/22/2018

**Contact:** Jim Hodges,

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	8/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
159		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

## Facility Summary in CHOUTEAU County in the City of FORT BENTON

**Location:** MOUNTAIN VIEW COOP FORT BENTON  
1820 SAINT CHARLES ST  
FORT BENTON, MT 59442 CHOUTEAU  
**Contact:** Buck Pandis, (406) 622-5121

**Sys Fac ID:** 08-00005  
**Last Inspected On:** 2/14/2014  
**Operating Permit Renewal Date:** 6/19/2017

**Owners/Operators:** Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS  
2200 OLD HAVRE HWY  
BLACK EAGLE MT 59414-1043

Patricia Holskey, UST Class A Operator  
Pat Trainor, UST Class A Operator  
Patricia Holskey, UST Class B Operator  
David Douglas, UST Class B Global Operator  
Pat Trainor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	39	12/11/1976	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>1021</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
6	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>1025</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>1023</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
8	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>1024</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in CHOUTEAU County in the City of FORT BENTON

**Location:** MOUNTAIN VIEW COOP FORT BENTON  
1820 SAINT CHARLES ST  
FORT BENTON, MT 59442 CHOUTEAU  
**Contact:** Buck Pandis, (406) 622-5121

**Sys Fac ID:** 08-00005  
**Last Inspected On:** 2/14/2014  
**Operating Permit Renewal Date:** 6/19/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>1022</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
16	13	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4628</b>		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		
17	13	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4629</b>		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		
18	13	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4630</b>		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		
19	13	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4631</b>		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		



## Facility Summary in CHOUTEAU County in the City of FORT BENTON

**Location:** MOUNTAIN VIEW COOP FORT BENTON  
1820 SAINT CHARLES ST  
FORT BENTON, MT 59442 CHOUTEAU

**Contact:** Buck Pandis, (406) 622-5121

**Sys Fac ID:** 08-00005  
**Last Inspected On:** 2/14/2014  
**Operating Permit Renewal Date:** 6/19/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
20	13	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4632</b>		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
30,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		
21	13	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4633</b>		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
30,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in CHOUTEAU County in the City of FORT BENTON

**Location:** JOYCE STORE 1  
1221 MAIN ST PO BOX 1208  
FORT BENTON, MT 59442 CHOUTEAU  
**Contact:** Kevin Joyce, (406) 622-3381

**Sys Fac ID:** 08-00093  
**Last Inspected On:** 10/24/2013  
**Operating Permit Renewal Date:** 11/20/2016

**Owners/Operators:** Riverside Business Inc, Owner (406)-586-3531 5809 GOOCH HILL RD  
BOZEMAN MT 59718-9060

Perry Joyce, UST Class A Operator  
Teresa Sparks, UST Class A Operator  
Jennifer Ritland, UST Class B Operator  
Teresa Sparks, UST Class B Operator  
Kevin Joyce, UST Class B Global Operator  
Jessica Smith, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	16	6/1/1999	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>4134</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/10/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
5	16	6/1/1999	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>4135</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/10/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
6	16	6/1/1999	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>4136</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/10/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					

## Facility Summary in CHOUTEAU County in the City of FORT BENTON

**Location:** COUNTY COURTHOUSE & JAIL  
1215 WASHINGTON ST  
FORT BENTON, MT 59442 CHOUTEAU

**Sys Fac ID:** 08-05930

**Last Inspected On:** 4/3/2014

**Operating Permit Renewal Date:** 9/9/2017

**Contact:** Bob Stevenson, (406) 622-3631

**Owners/Operators:** Choteau County, Owner

(406)-622-3631

PO BOX 459

FORT BENTON MT 59442-0459

Robert C Stevenson, UST Class A Operator

Michael Hingiss, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	27	6/1/1988	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4118		6/13/2014	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Manual Tank Gauging	Manual Interstitial Monitor	
550					

## Facility Summary in CHOUTEAU County in the City of FORT BENTON

**Location:** JOYCE FUEL & FEEDS FORT BENTON  
2118 SAINT CHARLES ST  
FORT BENTON, MT 59442 CHOUTEAU  
**Contact:** Brad Bramlette, (406) 622-3363

**Sys Fac ID:** 56-13981  
**Last Inspected On:** 12/8/2014  
**Operating Permit Renewal Date:** 1/14/2018

**Owners/Operators:** Perry Joyce, Owner (406)-737-4561 PO BOX 66  
GERALDINE MT 59446-0066  
Perry Joyce, UST Class A Operator  
Bradley Bramlette, UST Class B Operator  
Cody Joyce, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	15	7/27/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4210</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	15	7/27/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4211</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	15	7/27/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4212</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

## Facility Summary in CHOUTEAU County in the City of GERALDINE

**Location:** CENTRAL MONTANA COOP GERALDINE  
MT HIGHWAY 80  
GERALDINE, MT 59446 CHOUTEAU  
**Contact:** Bruce Clark, (406) 737-4480

**Sys Fac ID:** 08-06615  
**Last Inspected On:** 2/17/2016  
**Operating Permit Renewal Date:** 7/8/2016

**Owners/Operators:** Central Montana Coop Geraldine, Owner (406)-737-4480 PO BOX 330  
GERALDINE MT 59446-0330  
Danny Rowland, UST Class A Operator  
TOM BURTCHETT, UST Class B Operator  
Matthew Little, UST Class B Operator  
Jon Mcomber, UST Class B Operator  
Peter Rice, UST Class B Operator  
Danny Rowland, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	41	4/29/1974	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>864</b>	Yes		None	None	No
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
2,000		5/13/2013			
2	41	4/29/1974	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>865</b>	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
2,000		5/13/2013			

## Facility Summary in CHOUTEAU County in the City of HIGHWOOD

**Location:** HIGHWOOD SERVICE CENTER UST  
277 BROADWAY AVE W  
HIGHWOOD, MT 59450 CHOUTEAU

**Sys Fac ID:** 08-12320

**Last Inspected On:** 10/22/2015

**Operating Permit Renewal Date:** 11/25/2018

**Contact:** Richard Schott, (406) 733-5251

**Owners/Operators:** Richard L Schott, Owner

(406)-733-6072

3199 BURLEY HILL RD  
HIGHWOOD MT 59450-0026

Richard L Schott, UST Class A Operator

Richard L Schott, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3112</b>			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, Deferred	
1,000					
2	24	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3113</b>			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, Deferred	
1,000					

## Facility Summary in CHOUTEAU County in the City of LOMA

**Location:** PA'S MART  
204 BROADWAY  
LOMA, MT 59460 CHOUTEAU

**Sys Fac ID:** 08-01445

**Last Inspected On:** 6/4/2015

**Operating Permit Renewal Date:**

**Contact:** Gregory Bouchard, (406) 739-4422

**Owners/Operators:** Gregory Bouchard, Owner (406)-739-4422 204 BROADWAY AVE  
LOMA MT 59460

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	29	12/30/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3957</b>			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/29/2012	Inventory Reconciliation, Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
6,000					
2	29	12/30/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3958</b>			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/29/2012	Inventory Reconciliation, Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
6,000					

## Facility Summary in CHOUTEAU County in the City of RURAL LOCATION

**Location:** MALMSTROM AFB J 4  
 US HIGHWAY 87  
 RURAL LOCATION, MT CHOUTEAU  
**Contact:** Jim Hodges,

**Sys Fac ID:** 08-09077  
**Last Inspected On:** 9/21/2015  
**Operating Permit Renewal Date:** 9/22/2018

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
 MALMSTROM AFB MT 59402-7536  
 Lana Hedlund, UST Class A Operator  
 James Hodges, UST Class A Operator  
 Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
158		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		



## Facility Summary in CHOUTEAU County in the City of RURAL LOCATION

**Location:** MALMSTROM AFB J 6  
 US HIGHWAY 87  
 RURAL LOCATION, MT CHOUTEAU  
**Contact:** Jim Hodges,

**Sys Fac ID:** 08-09079  
**Last Inspected On:** 11/4/2015  
**Operating Permit Renewal Date:** 11/9/2018

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
 MALMSTROM AFB MT 59402-7536  
 Lana Hedlund, UST Class A Operator  
 James Hodges, UST Class A Operator  
 Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	00	7/6/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter, High Level Alarm
<b>5590</b>		6/29/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes

## Facility Summary in CHOUTEAU County in the City of RURAL LOCATION

**Location:** MALMSTROM AFB J 7  
US HIGHWAY 87  
RURAL LOCATION, MT CHOUTEAU

**Contact:** Jim Hodges,

**Sys Fac ID:** 08-09080  
**Last Inspected On:** 9/21/2015  
**Operating Permit Renewal Date:** 9/22/2018

**Owners/Operators:** 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N  
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator  
James Hodges, UST Class A Operator  
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
161		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		